



产品认证证书

证书编号: CQC2002010307003504

申请人名称及地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

制造商名称及地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产企业名称及地址

浙江天正电气股份有限公司(V038950)
浙江省乐清市经济开发区中心大道 288 号

产品名称和系列、规格、型号

万能式断路器

DW15-630,DW15C-630Ue:AC380V;In:100A,160A,200A,315A,400A,630A;过电流脱扣器类型:热磁式;lcs/lcu:lcs=lcu=20kA(100A,160A,200A);lcs=lcu=30kA(315A,400A,630A);使用类别:A类;极数:3P

产品标准和技术要求

GB 14048.2-2008

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求,特发此证。

发证日期:2020年05月29日 有效期至:2020年11月19日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任:

陆楠



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0283948



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2002010307003504

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Tengen Electrics Co.,Ltd.
Sulv Industry Zone, Liushi, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Tengen Electrics Co.,Ltd.
Sulv Industry Zone, Liushi, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Tengen Electrics Co.,Ltd. (V038950)
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION

Conventional Circuit-Breaker

DW15-630,DW15C-630Ue:AC380V;In:100A,160A,200A,315A,400A,630A;Over current release type:Thermal-magnetic type;lcs/lcu: lcs=lcu=20kA(100A,160A,200A);lcs=lcu=30kA(315A,400A,630A);Utilization Category:A;Poles:3P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: May.29,2020

Valid until: Nov.19,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>