

产品认证证书

II型自愿认证

证书编号: CQC2013010305593748

发证日期: 2020年08月24日

有效期至: 2031年05月20日

委托人名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

制造商名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

生产企业名称 浙江天正电气股份有限公司
及生产地址 浙江省乐清市柳市镇柳乐路332号

产品名称和系列、规格、型号 万能转换开关
LW5-16; Ui: 500V; Uimp: 2.5kV; AC-15: Ue/Ie: AC500V/2.6A; DC-13: Ue/Ie: DC440V/0.27A; Ith: 16A; 型号解释详见附件

产品标准和技术要求 GB/T14048.5-2017

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕 陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0056345

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2013010305593748

Valid from: Aug.24,2020

Valid until: May.20,2031

NAME AND REGISTERED
ADDRESS OF THE APPLICANT

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND LOCATION
OF THE FACTORY

Zhejiang Tengen Electric Co.,Ltd.
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL
AND SPECIFICATION

CAM switch
LW5-16 ; Ui : 500V ; Uimp : 2.5kV ; AC-15 : Ue/Ie : AC500V/2.6A ; DC-13 : Ue/Ie : DC440V/0.27A ;
Ith : 16A ; See the Appendix for type explanation

THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS

GB/T14048.5-2017

TYPE OF CERTIFICATION
SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

SIGNATURE

陈昕 陆楠



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0056345

产品认证证书

II型自愿认证


附 录

证书编号: CQC2013010305593748

第 1 页 共 3 页

纸 号: 56345

型号的解释:



注: 此附录与证书同时使用时有效。



中国质量认证中心



产品认证证书


II型自愿认证

附 录

证书编号: CQC2013010305593748

第 2 页 共 3 页

纸 号: 56345



注: 此附录与证书同时使用时有效。



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

产品认证证书

II型自愿认证

附录

证书编号: CQC2013010305593748

第 3 页 共 3 页

纸 号: 56345

操作方式		特征代号		操作器位置													
自定型	A						0°←	45°									
	B					45°→	0°←	45°									
定位型	C						0°	45°									
	D					45°	0°	45°									
	E					45°	0°	45°	90°								
	F				90°	45°	0°	45°	90°								
	G				90°	45°	0°	45°	90°	135°							
	H			135°	90°	45°	0°	45°	90°	135°							
	I			135°	90°	45°	0°	45°	90°	135°	180°						
	J		120°	90°	60°	30°	0°	30°	60°	90°	120°						
	K		120°	90°	60°	30°	0°	30°	60°	90°	120°	150°					
	L	150°	120°	90°	60°	30°	0°	30°	60°	90°	120°	150°					
	M	150°	120°	90°	60°	30°	0°	30°	60°	90°	120°	150°	180°				
	N					45°		45°									
	P					90°	0°	90°									
	YH						0°	90°	180°	270°							
				135°	90°	45°	0°	45°	90°	135°							
	LH						0°	90°	180°	270°							
	TM		30°	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°			
			30°	0°	30°	60°	90°	120°	150°	180°	210°	240°					
			30°	0°	30°	60°	90°	120°	150°	180°							
			30°	0°	30°	60°	90°	120°									
			45°	0°	45°	90°	135°	180°	225°	270°							
			22.5°	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°	247.5°	270°	

注: 此附录与证书同时使用有效。



中国质量认证中心

