

Zhejiang Tengen Electric Co., Ltd.
Li Li
-
Sulv Industrial Area,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P. R. China

Date : 23.09.2019
Our ref. : YQ ZC10
Your ref.: L.L.

Ref : R TÜV-Mark Approval

Type of Equipment : Three Phase Control Transformer
Model Designation : See Certificate
Certificate No. : R 50447375 0001
Report No. : 50271350 001

Dear Li Li,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body



James Li

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50447375

Blatt *Sheet*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum	<i>Date of Issue</i>
L.L.	ZC10-YQ-50271350 001	23.09.2019	(day/mo/yr)

Genehmigungsinhaber *License Holder*

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P. R. China

Fertigungsstätte *Manufacturing Plant*

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P. R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

EN 61558-1:2005+A1
EN 61558-2-2:2007

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

Lizenzentgelte - Einheit *License Fee - Unit*

Transformator (Three Phase Control Transformer)

Type Designation	: SBK-uVA v/w x y z (Tengen (Logo))	5
	u = 50, 60, 63, 80, 100, 150, 200,	1
	250, 300, 400, 500, 750, 900,	
	1000, 1200, 1500, 2000, 2500,	
	3000, 3500, 4000, 5000, 6000,	
	6300, 7500, 8000, 10K, 12K, 15K,	
	16.5K, 20K, 22K, 25K, 30K, 40K,	
	45K, 50K, 55K, 60K, 70K, 75K,	
	80K, 86K, 100K, 110K, 160K	
	v = 10V-1000V in Steps of 1	1
	w = 10V-1000V in Steps of 1	1
	x = Blank, 10V-1000V in Steps of 1	1
	y = Blank, 10V-1000V in Steps of 1	1
	z = Blank, 10V-1000V in Steps of 1	1
Rated Supply Voltage	: 10V-1000V in Steps of 1; 50/60Hz	
Rated Output Voltage	: 10V-1000V in Steps of 1; 50/60Hz	

Continued on page 0002

11

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com

Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



James Li

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50447375

Blatt *Sheet*
0002

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum	<i>Date of Issue</i>
L.L.	ZC10-YQ-50271350 001	23.09.2019	(day/mo/yr)

Genehmigungsinhaber *License Holder*

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P. R. China

Fertigungsstätte *Manufacturing Plant*

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P. R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

EN 61558-1:2005+A1
EN 61558-2-2:2007

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

Lizenzentgelte - Einheit *License Fee - Unit*

Transformator (Three Phase Control Transformer)

Continuation from page 0001

Rated Thermal Output (VA): 50, 60, 63, 80, 100, 150, 200,
250, 300, 400, 500, 750, 900,
1000, 1200, 1500, 2000, 2500,
3000, 3500, 4000, 5000, 6000,
6300, 7500, 8000, 10K, 12K, 15K,
16.5K, 20K, 22K, 25K, 30K, 40K,
45K, 50K, 55K, 60K, 70K, 75K,
80K, 86K, 100K, 110K, 160K

Rated Ambient Temperature: 40°C

Insulation Class : Class B for not more than 10KVA,
Class F for Others

Protection Degree : IP00

Method of Installation : Built-in

Protection Class : Class I

Short-circuit Proof : Non-short-circuit Proof
Transformer, Protected by Circuit
Breaker by Final Installed

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



James Li

Zhejiang Tengen Electric Co., Ltd.
Li Li
-
Sulv Industrial Area,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P. R. China

Date : 23.09.2019
Our ref. : YQ ZC10
Your ref.: L.L.

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Three Phase Control Transformer
Model Designation : See Certificate
Certificate No. : AN 50447376 0001
Report No. : 50271350 001

Dear Li Li,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body



James Li

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

C E R T I F I C A T E



of Conformity
Low Voltage Directive 2014/35/EU

Registration No.: AN 50447376 0001

Report No.: 50271350 001

Holder: Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P. R. China

Product: Transformer
(Three Phase Control Transformer)

Identification: Type Designation: SBK-uVA v/w x y z (Tengen (Logo))

Serial No.: n.a.

Remark: Issued in conjunction with TÜV Rheinland
license R 50447375 0001.

See more module type designations in attachment 1.1

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body

Date 23.09.2019



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

TÜV Rheinland
LGA Products GmbH
Tillystraße 2, 90431 Nürnberg

1.1


Attachment to
Registration No.: AN 50447376 0001
Report No.: 50271350 001

Manufacturer: Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P. R. China

Scope:

u = 50, 60, 63, 80, 100, 150, 200, 250, 300, 400, 500, 750,
900, 1000, 1200, 1500, 2000, 2500, 3000, 3500, 4000,
5000, 6000, 6300, 7500, 8000, 10K, 12K, 15K, 16.5K,
20K, 22K, 25K, 30K, 40K, 45K, 50K, 55K, 60K, 70K, 75K,
80K, 86K, 100K, 110K, 160K
v = 10V-1000V in Steps of 1
w = 10V-1000V in Steps of 1
x = Blank, 10V-1000V in Steps of 1
y = Blank, 10V-1000V in Steps of 1
z = Blank, 10V-1000V in Steps of 1
(Tengen (Logo))

Cologne, 23.09.2019


James Li

