



中国国家强制性产品认证证书

证书编号: 2002010303024972

委托人名称、地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产者(制造商)名称、地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产企业名称、地址

浙江天正电气股份有限公司
浙江省乐清市经济开发区中心大道 288 号

产品名称和系列、规格、型号

熔断器式开关

HR3□-100/3□;型号解释详见附件;Uimp:8kV; Ui:660V; Ie=Ith: 32A、40A、50A、63A、
80A、100A; Ue:AC380V; Iq: 50kA; 使用类别:AC-22B; 3P

产品标准和技术要求

GB/T14048.3-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2018 年 09 月 14 日 有效期至: 2020 年 05 月 13 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2002 年 12 月 12 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主 任:

中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2002010303024972

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Tengen Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Fuse-switch
HR3□-100/3□; Uimp:8kV; Ui:660V; Ie=Ith: 32A、40A、50A、63A、80A、100A; Ue:AC
380V; Iq: 50kA; Utilization Category:AC-22B; 3P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Sep.14,2018

Valid until: May.13,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Dec.12,2002

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

证书编号：2002010303024972

第 1 页 共 1 页

纸 号：

型号的解释：

HR 3 □ - 100 / 3 □

2 代表正面中央杠杆传动机构式，3 代表侧面操作手柄式，
4 代表侧方杠杆传动机构式

极数：3—三极

额定工作电流(A)

“BX”表示旋转型，正面中央杠杆传动机构；无“BX”代表杠杆式操作型

设计代号

熔断器式开关

注：此附录与证书同时使用时有效。



主 任：

中国质量认证中心