



中国国家强制性产品认证证书

证书编号: 2011010302470777

委托人名称、地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产者(制造商)名称、地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产企业名称、地址

浙江天正电气股份有限公司
浙江省乐清市经济开发区中心大道 288 号

产品名称和系列、规格、型号

熔断器式隔离开关

HR6-□/30, HR6-□/31; Ui: 1000V; Uimp: 12kV; Ith: 80A、100A、125A、160A、200A、250A; Ue:
AC380V/400V/415V, AC660V/690V; Ie: 80A、100A、125A、160A、200A、250A; Iq: 50kA; 使用类
别: AC-23B(380V/400V/415V), AC-22B(660V/690V); 极数: 3P; 配用的辅助触头: JW2-11; 1NO1NC;
Ui: 220V; Ith: 3A; AC-15: Ue/Ie: 220V/0.5A; DC-13: Ue/Ie: 220V/0.1A. 型号解释详见附件

产品标准和技术要求

GB/T14048.3-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2018 年 10 月 17 日 有效期至: 2021 年 03 月 28 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2011 年 04 月 22 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主 任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2011010302470777

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Tengen Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Fuse-switch Disconnector

HR6-□/30, HR6-□/31; Ui: 1000V; Uimp: 12kV; Ith: 80A, 100A, 125A, 160A, 200A, 250A; Ue: AC 380V/400V/415V, AC660V/690V; Ie: 80A, 100A, 125A, 160A, 200A, 250A; Iq: 50kA; Utilization Category: AC-23B(380V/400V/415V), AC-22B(660V/690V); Poles: 3P; Attached Auxiliary Contacts: JW2-11; 1 NO1NC; Ui: 220V; Ith: 3A; AC-15: Ue/Ie: 220V/0.5A; DC-13: Ue/Ie: 220V/0.1A. See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Oct.17,2018

Valid until: Mar.28,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Apr.22,2011

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666

Q 2085990



中国国家强制性产品认证证书

变更结论 Modification Approval

证书编号 Certificate No. : 2011010302470777

申请编号 Application No. : A2018CCC0302-2944845

申请人(委托人) Applicant: 浙江天正电气股份有限公司 / Zhejiang Tengen Electric Co.,Ltd.

证书编号 Certificate No.(变更前 Original): 2011010302470777

变更产品名称: 熔断器式隔离开关

Name of Product Modified: Fuse-switch Disconnecter

变更情况 Situation of Modification (见下表 See table below) :

序号	项目 Item	变更前 Original	变更后 Present
1	国家标准变更	GB/T 14048.3-2008 ;	GB/T 14048.3-2017;
2	型号变更	HR6-250/30, HR6-250/31 ;	HR6-□/30, HR6-□/31;
3	污染等级变更	/;	3 ;
4	辅助回路额定冲击耐 受电压变更	/;	1.5kV ;

现批准以上变更。

Above Modification is approved. The present will replace the original.

批准日期 (Date) : 2018 年 10 月 17 日

第 1 页 / 共 1 页



主 任 :



中国质量认证中心



中国国家强制性产品认证证书

附 录

证书编号: 2011010302470777

第 1 页 共 1 页

纸 号: 2085990

型号的解释:

HR 6 - □ / 3 □

(1) (2) (3) (4) (5)

(1) 熔断器式隔离开关;

(2) 设计代号;

(3) 额定工作电流 (A): 80、100、125、160、200、250;

(4) 极数: 3-3P;

(5) 开合信号装置代号: “0”表示无开合信号装置型; “1”表示有开合信号装置型;

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心