

产品认证证书

II型自愿认证

证书编号: CQC2014010307695286

发证日期: 2020年05月29日

有效期至: 2031年05月20日

委托人名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

制造商名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

生产企业名称 浙江天正电气股份有限公司
及生产地址 浙江省乐清市经济开发区中心大道288号

产品名称和系列、规格、型号 塑料外壳式断路器
TGM1E-125L, TGM1E-125M, TGM1E-125H; 参数及型号解释详见附件

产品标准和技术要求 GB/T14048.2-2008

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕 陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0056376

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2014010307695286

Valid from: May.29,2020

Valid until: May.20,2031

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND LOCATION
OF THE FACTORY**

Zhejiang Tengen Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province, P.R.China

**PRODUCT NAME, MODEL
AND SPECIFICATION**

Moulded Case Circuit-Breaker
TGM1E-125L, TGM1E-125M, TGM1E-125H; See the Appendix

**THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS**

GB/T14048.2-2008

**TYPE OF CERTIFICATION
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

C(2) 0056376

产品认证证书

II型自愿认证

附 录

证书编号: CQC2014010307695286

第 1 页 共 3 页

纸 号: 56376

TGM1E-125L, TGM1E-125M, TGM1E-125H

Ui: 800V; Uimp: 8kV; Ue: AC400V/AC690V(仅 M 型);

In: 32A(16A,20A,25A,32A 可调),

63A(32A,35A,40A,45A,50A,55A,60A,63A 可调),

125A(63A,65A,70A,75A,80A,85A,90A,95A,100A,125A 可调);

过电流脱扣器类型: 电子式;

Ics: 400V: 22kA(L 型), 35kA(M 型), 50kA(H 型);

690V: 10kA(M 型);

Icu: 400V: 35kA(L 型), 50kA(M 型), 85kA(H 型);

690V: 20kA(M 型);

Icw: 2kA/1.0s(L、M、H 型);

使用类别: A 类;

极数: 3P(3 个保护极,适用于隔离); 4P(3 个保护极,N 极可开闭,仅 M、H 型,适用于隔离,);

配用的辅助触头: 1NO1NC,2NO2NC; Ith: 3A;

AC-15: Ue/Ie: AC380V/AC400V/0.3A;

注: 此附录与证书同时使用时无效。



中国质量认证中心



产品认证证书

II型自愿认证

附录

证书编号: CQC2014010307695286

第 2 页 共 3 页

纸 号: 56376

DC-13: U_e/I_e : DC220V/DC230V/0.15A

型号的解释:

TG M 1 E- 125 ☐ ☐ ☐ / ☐ ☐ ☐ ☐
① ② ③ ④ ⑤ ⑥ ⑦ ⑧ ⑨ ⑩ ⑪ ⑫

①TG: 企业代号

②M: 塑料外壳式断路器

③1: 设计序号

④E: 电子式

⑤125: 壳架等级额定电流 (A)

⑥☐: 额定短路分断能力级别 (L--标准型; M--较高分断型; H--高分断型)

⑦☐: 操作方式 (无: 直接操作; P: 电动操作; Z: 转动手柄操作)

⑧☐: 极数代号 (3: 三极; 4: 四极)

⑨☐: 附件代号 (见表)

⑩☐: 接线方式代号 (无: 板前接线; C: 插入式接线)

⑪☐: 过载报警不跳闸带 "III"

注: 此附录与证书同时使用时有效。



中国质量认证中心



产品认证证书

II型自愿认证

附 录

证书编号: CQC2014010307695286

第 3 页 共 3 页

纸 号: 56376

⑫□: 控制器功能代号 (无: 六旋钮; E1: 三旋钮)

附表 1 脱扣器方式及附件代号

附件名称	无	报警触头	分励脱扣器	辅助触头	欠压脱扣器	分励脱扣器辅助触头	分励脱扣器欠压脱扣器
脱扣器型式及附件代号	300	308	310	320	330	340	350
附件名称	二组辅助触头	辅助触头 欠压脱扣器	分励脱扣器报警触头	辅助触头报警触头	欠压脱扣器报警触头	分励脱扣器辅助触头报警触头	
脱扣器型式及附件代号	360	370	318	328	338	348	

注: 此附录与证书同时使用时有效。



中国质量认证中心

