



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE220303007551

Product

Moulded Case Circuit Breaker

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model

TGM3-63L, TGM3-63M, TeM5-63L, TeM5-63M;

Technical data

Uimp:8kV; Ui: 800V;
Ue:AC380V/400V/415V;In:10A,15A,16A,20A,25A,30A,32A,40A,50A,60A,63A;Type of over-current release: Thermal-magnetic, Electro-magnetic; Type L: Ics:18kA,Icu:25kA;Type M: Ics:25kA,Icu:35kA; Selectivity category: A; 3P,3P+N(3 protected poles with an uninterrupted neutral pole),4P; 3P 4P: suitable for isolation; 3P+N: not suitable for isolation; Matching auxiliary contact:1NO1NC,2NO2NC,4NO4NC, Uimp:4kV; Ui:500V, Ith:3A,AC-15:380V/0.4A, DC-13:220V/0.15A; Matching alarm contact: NO1NC,2NO2NC,4NO4NC, Uimp:4kV;Ui:500V,Ith:3A,AC-15: 380V/0.4A,DC-13:220V/0.15A;Electronic accessory complying with annex N:Undervoltage release: Uimp:4kV;Ui:500V Us: AC(220/230/240)V, AC(380/400/415)V, 50HZ;Motor-operator: Uimp:4kV;Ui:500V; Us: AC(220/230/240)V,AC(380/400/415)V, 50HZ; Shunt release with prepayment: Uimp:4kV;Ui:500V Us:AC220V,AC380V, 50HZ

This is to certify that, on the basis of the tests undertaken as per Report No. (2021)FQIIDQCE-0228, the submitted sample(s) of the above item complies with:

EN 60947-2:2017/A1:2020; EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Jan.19,2022

Valid until: Jan.19,2025

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

CE 0012746