

产品认证证书

II型自愿认证

证书编号: CQC2014010302720493

发证日期: 2020年05月29日

有效期至: 2031年05月20日

委托人名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

制造商名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

生产企业名称 浙江天正电气股份有限公司
及生产地址 浙江省乐清市经济开发区中心大道288号

产品名称和系列、规格、型号 负荷隔离开关
GLZ-125/□□□, GLZ-160/□□□(型号解释详见附件); Uimp:6kV; Ui:690V; Ith:160A;
Ue:AC380V; Ie:125A, 160A; Icw:4kA/1s; Icm(峰值):5.88kA; AC-21B; 3P, 4P

产品标准和技术要求 GB/T14048.3-2017

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人 签发

陈昕 陆楠



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0056360

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2014010302720493

Valid from: May.29,2020

Valid until: May.20,2031

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND LOCATION
OF THE FACTORY**

Zhejiang Tengen Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province, P.R.China

**PRODUCT NAME, MODEL
AND SPECIFICATION**

Load Isolation Switches
GLZ-125/□□□, GLZ-160/□□□; Uimp:6kV; Ui:690V; Ith:160A; Ue:AC380V; Ie:125A,160A;
Icw:4kA/1s; Icm(Peak):5.88kA; AC-21B; 3P,4P

**THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS**

GB/T14048.3-2017

**TYPE OF CERTIFICATION
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0056360

产品认证证书

II型自愿认证

附 录

证书编号: CQC2014010302720493

第 1 页 共 1 页

纸 号: 56360

型号的解释:

<u>GL</u>	<u>Z</u>	<u>□</u>	/	<u>□</u>	<u>□</u>	<u>□</u>
(1)	(2)	(3)		(4)	(5)	(6)

(1) 负荷隔离开关

(2) 转化型

(3) 额定电流(A): 125、160

(4) 极数: 3 表示 3P, 4 表示 4P

(5) J: 表示柜外操作, 不标注: 表示柜内操作

(5) Z: 表示左右转换, 不标注: 表示上下转换

注: 此附录与证书同时使用时有效。



中国质量认证中心

