



产品认证证书

证书编号: CQC2002010305025045

申请人名称及地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

制造商名称及地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产企业名称及地址

浙江天正电气股份有限公司(V038950)
浙江省乐清市经济开发区中心大道 288 号

产品名称和系列、规格、型号

刀开关

HD□-250、HS□-250; Uimp: 12kV; Ui: 1000V; Ue: AC415V/690V; Ith: 250A; Ie: 250A、200A; Icw: 10kA/1s;
Iq: 50kA; AC-20A(Ue: AC415V/690V); AC-21B(Ue: AC415V); HD12-250、HD13-250、HD13BX-250、HD14-250、
HS12-250、HS13-250、HS13BX-250); 极数: 2P、3P、4P; 配用的辅助触头: 1NO1NC; Ith: 5A; AC-15: Ue/Ie:
380V/0.8A; DC-13: Ue/Ie: 220V/0.1A; 型号解释见附件

产品标准和技术要求

GB/T14048.3-2017

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462143-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 05 月 29 日 有效期至: 2024 年 11 月 20 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0280061



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2002010305025045

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Tengen Electric Co.,Ltd. (V038950)
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Knife Switch

HD□-250、HS□-250: Uimp: 12kV; Ui: 1000V; Ue: AC415V/690V; Ith: 250A; Ie: 250A、200A; Icw: 10kA/1s; Iq: 50kA; AC-20A(Ue: AC415V/690V); AC-21B(Ue: AC415V; HD12-250、HD13-250、HD13BX-250、HD14-250、HS12-250、HS13-250、HS13BX-250); Poles: 2P、3P、4P; Auxiliary contacts: 1NO1NC; Ith: 5A; AC-15: Ue/Ie: 380V/0.8A; DC-13: Ue/Ie: 220V/0.1A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.3-2017

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462143-2019 .

Valid from: May.29,2020

Valid until: Nov.20,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0280061



产品认证证书

附录

证书编号: CQC2002010305025045

第 1 页 共 1 页

纸 号: 280061

型号解释:

□ □ □ - □ / □ □ □
(1) (2) (3) (4) (5) (6) (7)

- (1) “HD” 表示单投刀开关, “HS” 表示双投刀开关;
- (2) 设计代号: 11: 中央手柄式; 12: 侧方正面杠杆操作机构式; 13: 中央杠杆操作机构式;
14: 侧面手柄式;
- (3) 附加代号可不注: 仅对 “HD11” 系列带 “F” 表示带防护罩;
仅对 “13” 系列带 “BX” 表示旋转式操作, 无 “BX” 表示杠杆式操作;
- (4) 约定发热电流 (A): 250
- (5) 极数: 2-2P、3-3P、4-4P; 仅对 “11” 系列 2P 使用
- (6) 0 表示不带灭弧罩; 1 表示有灭弧罩; 仅对 “11” 系列: 8 表示板前接线; 9 表示板后接线;
- (7) 仅对 “11” 系列 “B” 表示保护型; 仅对 “HD11F” 系列 “0” 表示不带锁,
“1” 表示带锁, 配一常开一常闭辅助;

注: 此附录与证书同时使用时有效。

主任:

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>