

产品认证证书

II型自愿认证

证书编号: CQC2019010302265892

发证日期: 2020年05月29日
有效期至: 2031年05月20日

委托人名称	浙江天正电气股份有限公司
及注册地址	浙江省乐清市柳市镇苏吕工业区
制造商名称	浙江天正电气股份有限公司
及注册地址	浙江省乐清市柳市镇苏吕工业区
生产企业名称	浙江天正电气股份有限公司
及生产地址	浙江省乐清市经济开发区中心大道 288 号
产品名称和系列、规格、型号	隔离开关 HH15(QA、QP)-400、HH15(QA、QP)-630 ; Uimp:12kV ; Ui:1000V ; Ue:AC415V/690V ; Ith:630A ; Ie: 400A , 630A ; Icw=12.6kA/1s ; Icm(峰值): 25.2kA ; 使用类别 : AC-23B(AC415V)/AC-22B(AC690V) ; 3P、3P+N、4P; 配用的辅助触头 : 1NO1NC、 2NO2NC , Uimp:2.5kV; Ui:660V; Ith:6A; AC-13:380V/6A; 型号解释详见附件
产品标准和技术要求	GB/T14048.3-2017
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

陈昕

签发

陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0057281

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010302265892

Valid from: May.29,2020

Valid until: May.20,2031

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND LOCATION
OF THE FACTORY**

Zhejiang Tengen Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province, P.R.China

**PRODUCT NAME, MODEL
AND SPECIFICATION**

Isolating switch
HH15(QA, QP)-400, HH15(QA, QP)-630 ; Uimp:12kV ; Ui:1000V ; Ue:AC415V/690V ; Ith:630A ;
Ie: 400A , 630A ; Icw=12.6kA/1s ; Icm(Peak Value): 25.2kA ; Utilization Category :
AC-23B(AC415V)/AC-22B(AC690V) ; 3P, 3P+N, 4P;Attached Auxiliary Contacts : 1NO1NC,
2NO2NC , Uimp:2.5kV; Ui:660V; Ith:6A; AC-13:380V/6A; See the Appendix for type explanation
GB/T14048.3-2017

**THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS**

**TYPE OF CERTIFICATION
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0057281

产品认证证书

II型自愿认证

附 录

证书编号: CQC2019010302265892

第 1 页 共 1 页

纸 号: 57281

型号的解释:

HH 15 (QA、QP) - □ / □ □
(1) (2) (3) (4) (5) (6)

(1) 隔离开关

(2) 设计序号

(3) 另一种型号: 隔离开关

(4) 额定工作电流: 400A, 630A

(5) 极数: 3—三极, 3+N—三极+直通 N 极, 4—三极+可通断 N 极

(6) “1” 表示带辅助触头一常开一常闭, “2” 表示带辅助触头二常开二常闭; 无则用 “0” 表示。

注: 此附录与证书同时使用时有效。



中国质量认证中心

