

# 产品认证证书

## II型自愿认证

证书编号: CQC2019010302265854

发证日期: 2020年05月29日

有效期至: 2031年05月20日

委托人名称

浙江天正电气股份有限公司

及注册地址

浙江省乐清市柳市镇苏吕工业区

制造商名称

浙江天正电气股份有限公司

及注册地址

浙江省乐清市柳市镇苏吕工业区

生产企业名称

浙江天正电气股份有限公司

及生产地址

浙江省乐清市经济开发区中心大道288号

产品名称和系列、

隔离开关

规格、型号

HH15(QA、QP)-1000、HH15(QA、QP)-1250、HH15(QA、QP)-1600; Uimp:8kV;  
Ui:1000V; Ue:AC415V/690V; Ith:1600A; Ie:1000A、1250A、1600A; Icw=50kA/1s;  
Icm(峰值):105kA; 使用类别:AC-22B(AC415V)/AC-21B(AC690V); 3P、4P; 配用的辅  
助触头:1NO1NC、2NO2NC, Uimp:2.5kV; Ui:660V; Ith:6A; AC-13:380V/6A; 型号解  
释详见附件

产品标准和技术要求

GB/T14048.3-2017

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人

签发

陈昕

陆楠



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0057280

# CERTIFICATE OF PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010302265854

Valid from: May.29,2020

Valid until: May.20,2031

**NAME AND REGISTERED  
ADDRESS OF THE APPLICANT**

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND REGISTERED  
ADDRESS OF THE  
MANUFACTURER**

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND LOCATION  
OF THE FACTORY**

Zhejiang Tengen Electric Co.,Ltd.  
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province, P.R.China

**PRODUCT NAME, MODEL  
AND SPECIFICATION**

Isolating switch  
HH15(QA, QP)-1000, HH15(QA, QP)-1250, HH15(QA, QP)-1600 ; Uimp:8kV ; Ui:1000V ;  
Ue:AC415V/690V ; Ith:1600A ; Ie: 1000A, 1250A, 1600A ; Icw=50kA/1s ; Icm(Peak Value): 105kA ;  
Utilization Category : AC-22B(AC415V)/ AC-21B(AC690V) ; 3P, 4P; Attached Auxiliary Contacts :  
1NO1NC, 2NO2NC , Uimp:2.5kV; Ui:660V; Ith:6A; AC-13:380V/6A; See the Appendix for type  
explanation

**THE STANDARDS AND  
TECHNICAL REQUIREMENTS  
FOR THE PRODUCTS**

GB/T14048.3-2017

**TYPE OF CERTIFICATION  
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.  
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGN BY

陈昕

SIGNATURE

陆柏



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0057280

# 产品认证证书

## II型自愿认证

### 附 录

证书编号: CQC2019010302265854

第 1 页 共 1 页

纸 号: 57280

型号的解释:

HH 15 (QA、QP) - □ / □ □

“1”表示带辅助触头一常开一常闭;

“2”表示带辅助触头二常开二常闭; 无则用“0”表示

极数: 3-三极, 3N-三极+直通 N 极, 4-三极+可通断 N 极

额定工作电流(A): 1000、1250、1600

特征代号: 隔离开关

设计序号

隔离开关

注: 此附录与证书同时使用时有效。



中国质量认证中心

